

Wiitta Ky  
Suokannaksentie 1  
FI-18300 Heinola  
Finland

## Ignitability according to DIN 4102 - B2

(1 appendix)

### Introduction

SP has by request of Wiitta OY performed a fire test according to DIN 4102 – B2. The purpose of the test is basis for technical fire classification.

### Product

According to the client: Material for sewage piping consisting of PP-copolymer Lyondell Basell H2464 or equivalent material + 2% color masterbatch. The typical product has a nominal bulk density of 900 kg/m<sup>3</sup> and a nominal thickness of 2 – 6 mm.

### Manufacturer

Wiitta OY, Heinola, Finland.

### Sampling

The sample was delivered by the client. It is not known to SP Fire Technology if the product received is representative of the mean production characteristics.

The sample was received on January 2, 2014 at SP Fire Technology.

### Test results

The product was tested with surface exposure and edge exposure.

The test results are given in appendix 1.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

### Criteria

According to DIN 4102, Part 1 (May 1998), section 6.2.1 and 6.2.5, a material is classified as class B2 if the following two criteria are met:

The flame tip must not reach the mark at 150 mm before the end of the 20th second of the test, edge exposure.

The flame tip must not reach the mark at 190 mm before the end of the 20th second of the test, surface exposure.

---

#### SP Technical Research Institute of Sweden

Postal address  
SP  
Box 857  
SE-501 15 BORÅS  
Sweden

Office location  
Västeråsen  
Brinellgatan 4  
SE-504 62 BORÅS

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

### Assessment

The tested product meets the technical fire requirements mentioned above.

### Note

The accreditation referred to is valid for DIN 4102 - B2.

According to DIN 4102-1, a report should normally not be older than five years.

### SP Technical Research Institute of Sweden Fire Research - Fire Dynamics

Performed by



Anna Bergstrand

Examined by



Per Thureson

### Appendix

1 Test results

Appendix 1

**Test results - DIN 4102, Part 1 - B2 (1998)**

**Product**

According to the client: Material for sewage piping consisting of PP-copolymer Lyondell Basell H2464 or equivalent material + 2% color masterbatch. The typical product has a nominal bulk density of 900 kg/m<sup>3</sup> and a nominal thickness of 2 – 6 mm.

**Application**

Surface exposure.

**Test results**

Test no	1	2	3	4	5
The sample ignited, s	NI	NI	NI	NI	NI
The flames reach 190 mm, s	-	-	-	-	-
Burning droplets, Y/N	No	No	No	No	No
Time when filter paper ignite, s	-	-	-	-	-
Damaged length, mm	-	-	-	-	-

NI = No Ignition

Edge exposure.

**Test results**

Test no	1	2	3	4	5
The sample ignited, s	4-5	4-5	3-4	3-4	5-6
The flames reach 150 mm, s	-	-	-	-	-
Burning droplets, Y/N	No	No	No	No	No
Time when filter paper ignite, s	-	-	-	-	-
Damaged length, mm	-	-	-	-	-

**Deviation from standard**

The relative humidity in the test room was too low according to standard but it is deemed to be a worst case scenario.

**Measured data**

Thickness 3.4 – 3.6 mm.

Density 900 kg/m<sup>3</sup> approximately.

## Appendix 1

**Conditioning**

Temperature ( $23 \pm 2$ ) °C.

Relative humidity ( $50 \pm 5$ ) %.

**Date of test**

January 22, 2014.